

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50470518

Blatt *Sheet*
0003

Ihr Zeichen *Client Reference*
245763844

Unser Zeichen *Our Reference*
01-Zhangzp-50284942 003

Ausstellungsdatum *Date of Issue*
18.02.2022 (day/mo/yr)

Genehmigungsinhaber *License Holder*
ABB Power Electronics Inc.
601 Shiloh Road Plano,
Texas 75074
USA

Fertigungsstätte *Manufacturing Plant*
Refer to latest revision
of the annex list of factories

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*
EN IEC 62368-1:2020+A11
EN 62368-1:2014+A11

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Einbau-Schaltnetzteil (Switching Power Supply)

as page 0001

Change

AC input: 100-240 V, 2.5 A, 47-63 Hz or
75-130 V (trapezoidal), 1.7 A, 47-63Hz or
100-240 V, 2.8 A, 47-63 Hz

Rated Output : refer to Appendix No. 1.2

Protection Class : Class I

Max. Operating Altitude : 5000m

Max. Operating Temperature: refer to Appendix No. 1.2

ANLAGE (Appendix): 1.2

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

<http://www.tuv.com/safety> E-mail: markcheck@tuv.com
Fax: +49 221 806-3935



Mark Chen